

5-Day

Allen Family Foods, Inc.

Allen Family Foods, Inc.

Phone:
FAX:
email:

May 7, 2007



Mr. Allen McCloskey
Department of Natural Resources & Environmental Control
Division of Water Resources
89 Kings Highway
Dover, Delaware 19901

Re: Permit #DE 0000299
Discharge 001

This letter is to follow up the 24 hour phone verification with your office that occurred on May 7, 2007 concerning the composite sample results for the sampling period 05-01-07 through 05-02-07. Per the notification requirements of Part II, Section A.2.(b) of the referenced permit we report the following:

Allen's - Harbeson 001 Composite Samples

Sample Dates	Parameter	Results Reported
05-01-07 to 05-02-07	Total Suspended Solids lbs/day	243.2 lbs/day

The above results of lbs/day Total Suspended Solids occurred on the sampling period noted above and were a result of accumulated solids in the chlorine contact chamber. The plant was briefly put into recycle on Friday, May 4, 2007 to allow the chlorine contact chamber to be drained and thoroughly cleaned.

If you should have any questions, please do not hesitate to contact me at (302) 684-1640, Ext. 184.

Respectfully submitted,
ALLEN FAMILY FOODS, INC.

A handwritten signature in blue ink that reads "Michael R. Sause".

Michael R. Sause
Wastewater Manager